

**§ 76.10-10 Fire station hydrants, hose and nozzles-T/ALL.**

(a) The size of fire hydrants, hose, and nozzles and the length of hose required shall be as noted in table 76.10-5(a).

(b) In lieu of the 2½-inch hose and hydrants specified in table 76.10-5(a), on vessels over 1,500 gross tons, the hydrants in interior locations may have siamese connections for 1½-inch hose. In these cases the hose shall be 75 feet in length, and only one hose will be required at each fire station; however, if all such stations can be satisfactorily served with 50-foot lengths, 50-foot hose may be used.

(c) On vessels of 500 gross tons and over there must be at least one shore connection to the fire main available to each side of the vessel in an accessible location. Suitable cut-out valves and check valves must be provided. Suitable adaptors also must be provided for furnishing the vessel's shore connections with couplings mating those on the shore fire lines. Vessels of 500 gross tons and over on an international voyage, must be provided with at least one international shore connection complying with ASTM F 1121 (incorporated by reference, see § 76.01-2). Facilities must be available enabling an international shore connection to be used on either side of the vessel.

(d) Fire hydrants shall be of sufficient number and so located that any part of the vessel, other than main machinery spaces, accessible to the passengers or crew while the vessel is being navigated and all cargo holds may be reached with at least two streams of water from separate outlets, at least one of which shall be from a single length of hose. For the purpose of this requirement, all watertight doors and all doors in main vertical zone bulkheads and stairway enclosures shall be closed, although hose ports may be installed in doors other than watertight doors and doors in main vertical zone bulkheads for the passage of the hose. In main machinery spaces, all portions at such spaces shall be capable of being reached by at least two streams of water, each of which shall be from a single length of hose from separate outlets; however, this re-

quirement need not apply to shaft alleys containing no assigned space for the stowage of combustibles. Fire hydrants shall be numbered as required by § 78.47-20 of this subchapter.

(e) All parts of the fire main located on exposed decks shall either be protected against freezing or be fitted with cut-out valves and drain valves so that the entire exposed parts of such piping may be shut off and drained in freezing weather. Except when closed to prevent freezing, such valves shall be sealed open.

(f) The outlet at each fire hydrant shall be provided with a cock or valve fitted in such a position that the fire hose may be removed while the firemain is under pressure. In addition, the outlet shall be limited to any position from the horizontal to the vertical pointing downward, so that the hose will lead horizontally or downward to minimize the possibility of kinking.

(g) Each fire hydrant must have at least one length of fire hose, a spanner, and a hose rack or other device for stowing the hose.

(h) Fire hose shall be connected to the outlets at all times. However, on open decks where no protection is afforded to the hose in heavy weather, or where the hose may be liable to damage from the handling of cargo the hose may be temporarily removed from the hydrant and stowed in an accessible nearby location.

(i) Fire hose shall not be used for any other purpose than fire extinguishing and fire drills.

(j) Each firehose on each hydrant must have a combination solid stream and water spray firehose nozzle that meets the requirements in subpart 162.027 of this chapter. Firehose nozzles previously approved under subpart 162.027 of this chapter may be retained so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

(k) Firehose nozzles previously approved under subpart 162.027 of this chapter must have low-velocity water spray applicators also previously approved under subpart 162.027 of this chapter as follows—

(1) In accommodation and service areas—two firehoses; and

## § 76.10-15

(2) In each propulsion machinery space containing an oil-fired boiler, internal combustion machinery, or oil fuel unit on a vessel on an international voyage or of 1000 gross tons or more—each firehose. The length of each applicator must be not more than 1.8 meters (6 feet).

(l) Fixed brackets, hooks, or other means for stowing an applicator must be next to each fire hydrant that has an applicator under paragraph (k) of this section.

(m) Fire hydrants, nozzles, and other fittings shall have threads to accommodate the hose connections noted in paragraph (l) of this section.

(n) Firehose and couplings must be as follows:

(1) Fire station hydrant connections shall be brass, bronze, or other equivalent metal. Couplings shall either—

(i) Use National Standard fire hose coupling threads for the 1½ inch (38 millimeter) and 2½ inch (64 millimeter) hose sizes, i.e., 9 threads per inch for 1½ inch hose, and 7½ threads per inch for 2½ inch hose; or

(ii) Be a uniform design for each hose diameter throughout the vessel.

(2) Each section of firehose must be lined commercial firehose that conforms to UL 19 (incorporated by reference; see 46 CFR 76.01-2). Hose that bears the label of Underwriters' Laboratories, Inc. as lined firehose is accepted as conforming to this requirement.

[CGFR 65-50, 30 FR 16940, Dec. 30, 1965]

EDITORIAL NOTE: For FEDERAL REGISTER citations affecting § 76.10-90, see the List of CFR Sections Affected, which appears in the Finding Aids section of the printed volume and at [www.fdsys.gov](http://www.fdsys.gov).

## § 76.10-15 Piping.

(a) All piping, valves, and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.

(b) All distribution cut-off valves shall be marked as required by § 78.47-15 of this subchapter.

(c) For vessels on an international voyage, the diameter of the fire main shall be sufficient for the effective distribution of the maximum required discharge from two fire pumps operating simultaneously. This is in addition to

## 46 CFR Ch. I (10-1-12 Edition)

§ 76.10-5(c). The discharge of this quantity of water through hoses and nozzles at a sufficient number of adjacent hydrants shall be at a minimum Pitot tube pressure of approximately 50 pounds per square inch.

## § 76.10-90 Installations contracted for prior to May 26, 1965.

(a) Installations contracted for prior to May 26, 1965, shall meet the following requirements:

(1) Except as specifically modified by this paragraph, the requirements of §§ 76.10-5 through 76.10-15 shall be complied with insofar as the number and general type of equipment is concerned. Existing equipment, except firehose nozzles and low-velocity water spray applicators, previously approved but not meeting the applicable requirements of §§ 76.10-5 through 76.10-15 may be continued in service so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs, alterations, and replacements may be permitted to the same standards as the original installation. However, all new installations or major replacements shall meet the applicable requirements in this part.

(2) All vessels contracted for prior to November 19, 1952, shall be fitted with fire pumps, hoses, and nozzles in accordance with table 76.10-90(a)(2).

TABLE 76.10-90(a)(2)

Gross tons		Minimum number of pumps	Minimum hose and hydrant size, inches	Nozzle orifice size, inches	Length of hose, feet
Over	Not over				
100 .....	4,000	2	1 1½	1 5/8	150
4,000 .....	.....	3	1 1½	1 5/8	150

<sup>1</sup> May use 50 feet of 2½-inch hose with 7/8-inch nozzles for exterior stations. May use 75 feet of 1½-inch hose with 5/8-inch nozzles for interior station in which case such interior stations shall have siamese connections.

(3) When reasonable and practicable, where two or more fire pumps are required, they shall not all be located in the same space. Vessels on an international voyage shall, however, comply with the requirements of § 76.10-5(h).

(4) The general requirements of § 76.10-5(c) through (h), § 76.10-10(d)